

Prime Sponsor(s): Mr. Toole
Date of Introduction: November 18, 2025

**FLOOR AMENDMENT NO. 5 TO
SUBSTITUTE NO. 2 TO ORDINANCE NO. 25-101**

Substitute No. 2 to Ordinance No. 25-101 is hereby amended at line numbers 188-193 by deleting the material there appearing as identified with strikethroughs and red below.

~~and providing the Total Usage Efficiency (“TUE”), the comprehensive metric for evaluating the overall energy efficiency of a system considering both the energy used by the IT equipment and the supporting infrastructure, with a minimum TUE of 1.15 must be provided unless operational issues are documented and accepted to vary this minimum~~

SYNOPSIS: This floor amendment proposes that the language currently appearing at line numbers 188-193, as highlighted in red above, be stricken.